

2005

---

# DOE Hydrogen Program Review

## 150 kW PEM Fuel Cell Power Plant Verification

Tom Clark

**UTC Fuel Cells**

May 26, 2005

Project ID # FC46

**Contract # DE-FC36-04GO14053**

# Overview

---

## Timeline

- Jan. 2, 2004 Start Date
- Dec. 31, 2009 End Date
- 20% Complete

## Budget

- Total project funding
  - DOE share \$11,617,821
  - Contractor share \$10,165,096.
- Funding FY04 \$1,337,306
- Funding FY05 \$1,562,694

## Barriers

- **Components**
  - O. Stack Material & Manufacturing Cost
  - P. Durability
  - Q. Electrode Performance
  - R. Thermal & Water Management
- **Distributed Generation Systems**
  - E. Durability
  - F. Heat Utilization
  - G. Power Electronics

## Partners

- United Technologies Research Center
- CT Light and Power
- EPRI
- Austin Energy
- New York Power Authority
- San Francisco Public Utilities Commission

# Objectives

---

- *The UTC Fuel Cells DOE Stationary Power Plant Program will resolve critical cell component, cell stack, and power plant reliability issues. Testing will be conducted in 20-cell stacks, and 150 kW power plants.*
  1. Improve PEM CSA durability to achieve lifetimes >40,000 Hrs
  2. Verify reliability of low cost PEM cell stack components
  3. Verify the Design, Durability, and Reliability of Natural Gas Fueled PEM Power Plant
  4. Complete a Fuel Cell Stationary Power Plant Market Assessment
  5. Waste Heat Thermal Integration Assessment

# CSA Technology Approach

---

- Improve PEM CSA durability to achieve lifetimes > 40,000 hrs by:
  - Determine root cause and corrective action for high severity / frequent CSA failure modes
  - Develop a mathematical modeling to optimize inlet flow channel design for maximum humidification
  - Identify seal materials with chemical and mechanical stability in a fuel cell environment
  - Verify accelerated test conditions that demonstrate representative failure modes
  - Endurance verification of durability improvements
- Cost reduction of PEM CSA components by validating low-cost plate and UEA components
  - Performance in single cell tests and
  - Durability in 20-cell tests

# CSA Technical Accomplishments


---

- Improved components and accelerated testing for CSA durability
  - Accelerated testing shows advanced reinforced membrane life-times of > 20-kh
  - Non-silicone materials for advanced designs down-selected
  - Seal accelerated testing suggests sealability maintained up to 40,000 Hrs
- Low cost component verification
  - Single cell performance verification of low cost plates and UEAs
- Endurance Testing
  - 11,500 hours on 20-cell stack with unreinforced membrane
  - 4,000+ hours on S900 20-cell stack

# Seal Durability Accomplishment

## Interfacial gasket CSR


Compression Set



Improved compression set resistance

15,000 → 43,000 hours

Predicted Lifetime





$$k = A \exp\left(\frac{-E}{RT}\right)$$

# Membrane Durability Accomplishment


## Cyclic accelerated testing

- Reinf1 84~100 h
- Reinf2 130 h
- Reinf5 180 h
  
- Unreinf 100 h
- Reinf3 ~160 h
- Reinf4 ~163 h



# Endurance Demonstration Accomplishment


4.5-kh on S900 20-cell and 11.5-kh on N111 20-cell





# CSA Cost Reduction

## Performance comparison Accomplishment



# Power Plant Approach

---

- Verify the specification, durability, and reliability of natural gas fueled PEM power plant
  - Operate PEM Beta Stationary power plant as a 150 kW baseline
  - Dynamic Controls Testing
  - Use Beta Test Article Results as a Baseline for Next Generation Verification Design
  - **Compete Improved Integrated System Design for Reliability**
  - Construct and Evaluate a PEM-150kW that incorporates significant Improvements in Power Plant Controls, **Fuel Processor Design**, Balance of Plant Components, and Grid Operation
- Complete a Fuel Cell Stationary Power Plant Market Assessment
  - Identify Market Segments, Drivers and Size
  - Identify Energy Credits and Incentives
  - Explore Domestic and International Opportunities
- Waste Heat Thermal Integration Assessment
  - Concepts,
  - Value Proposition Studies
  - Regional Needs Summary

# P/P Accomplishments

---


- Demonstration Testing of Beta Power Plant
  - Multiple daily runs: Typical 1 to 4 hour runs
  - Controls tuned for hands off automatic startup
  - Achieved maximum power of 139 kW DC / 117kW AC Net.
  - CO performance from FPS less than 10 ppm
  - FPS thermal management optimized
  - Debugged subsystems and BOP (balance of plant) components
  - P/P Start time reduced to 25 minutes
  - Cathode Humidification/Energy Recovery Device Verified
- Dynamic Tests Completed & Data Collected.
  - Tests conducted on 8 major loops: Power, Cathode air, CPO fuel & air flows, Prox air & thermal, Vaporizer water, CPO air blower
  - Tests conducted at 2 power levels: 40 kW and 75 kW.
  - Excitations used are step, sine-sweep and PRBS (pseudo random binary signal)
  - Dynamic data acquired at 10 Hz from the controller via CANalyzer

# Power Plant FPS Approach

---

- Design and test a Fuel Processor System (FPS) capable of delivering high purity H<sub>2</sub> (> 90%) to a PEM fuel cell
- Design FPS to resolve critical component durability and cost issues using UTCFC experience
- Design validation will be accomplished via a full scale (150 kW) integrated FPS test

# FPS Design Approach



<b>PC25 Configuration</b>
<b>Non UTCFC Hardware</b>
<b>PC35 Configuration</b>

# FPS Accomplishments



---

- 4 FPS design concepts were evaluated
- Reformer design based on Catalytic Steam Reforming (CSR)
- Examined the impact of reformat clean-up
  1. CO<sub>2</sub> Membrane (CO<sub>2</sub> Separation)
  2. Pd Alloy Membrane (H<sub>2</sub> Separation)
  3. Pressure Swing Adsorption (PSA)
  4. Preferential Oxidation (PROX)

# FPS Concept Options

	<u>Concept 1</u>	<u>Concept 2</u>	<u>Concept 3</u>	<u>Concept 4</u>
<b>FPS</b>	<b>Reformer Type - CSR</b>			
Operating Pressure	<b>4 bar</b>	<b>6 bar</b>	<b>10 bar</b>	<b>1 bar</b>
CH <sub>4</sub> Conversion	<b>90%</b>	<b>85%</b>	<b>75%</b>	<b>90%</b>
<b>Purification</b>				
Method	<b>CO<sub>2</sub> Membrane</b>	<b>H<sub>2</sub> Membrane</b>	<b>PSA</b>	<b>NONE - PROX</b>
H <sub>2</sub> purity	<b>97% dry</b>	<b>&gt;99%</b>	<b>&gt;99.9%</b>	<b>78% dry</b>
<b>CSA</b>	<b>CSA Type – S900</b>			
Anode Recycle	No	Yes	Yes	No
<b>Power Plant</b>				
FPS Efficiency	<b>73.9%</b>	<b>62.2%</b>	<b>73.9%</b>	<b>73.8%</b>
Mech. Efficiency	<b>97.0%</b>	<b>95.5%</b>	<b>94.9%</b>	<b>98.7%</b>
CSA Efficiency	52%	52%	52%	<b>51%</b>
System Efficiency	<b>37.2%</b>	<b>30.8%</b>	<b>36.4%</b>	<b>37.0%</b>
Technical Risk	<b>Membrane</b>	<b>Membrane</b>	<b>Reformer</b>	<b>CSA - Reformate</b>

# 150 kW Conceptual Layout





## Fuel Cell Stationary Power Plant Market Assessment Market Segments/ Drivers

Segments / Applications						
Commercial		Utility		Industrial		Government
Market Drivers	Combined Heat & Power (CHP)	Assured Power	<ul style="list-style-type: none"> <li>Power Supply</li> <li>T &amp; D Upgrade Avoidance</li> </ul>	<ul style="list-style-type: none"> <li>Conventional</li> <li>Specialty (H2)</li> </ul>	<ul style="list-style-type: none"> <li>US Military bases</li> <li>Municipal buildings</li> </ul>	<ul style="list-style-type: none"> <li>Municipal ADG</li> <li>Landfills</li> </ul>
Economic	<ul style="list-style-type: none"> <li>~ 3 year payback</li> <li>Energy Savings</li> </ul>	Lost productivity costs (varies)	Up to 10 year payback	<ul style="list-style-type: none"> <li>~3 - 5 year payback</li> <li>Low Electric Rates</li> </ul>	Longer paybacks possible	Longer paybacks possible
Technical	<ul style="list-style-type: none"> <li>Emissions / Noise</li> <li>Heat Quality</li> <li>Footprint</li> </ul>	Reliability	<ul style="list-style-type: none"> <li>Large power requirements (1+MW)</li> <li>High power density</li> <li>Low Emissions</li> </ul>	Multi MW needs	<ul style="list-style-type: none"> <li>Not always 24/7/365</li> <li>Emissions/ Noise</li> <li>Heat Quality</li> <li>Footprint</li> </ul>	Require Gas Processing Unit
Regulatory / Other Factors	<ul style="list-style-type: none"> <li>Availability of Incentives /Subsidies</li> <li>Utility Interconnection rules/tariffs</li> </ul>		<ul style="list-style-type: none"> <li>State PUCs RPS Standards</li> <li>Costs captured in regulated base</li> <li>Grid Constraints</li> </ul>			

## Fuel Cell Stationary Power Plant Market Assessment

- Domestic US Market
  - Direct Generation
  - Renewables (ADG)
  - On-Line Emergency Power
  - Assured Power
  - Micro-grid Power
  - Green Power / Cogeneration
- International Market Opportunities
  - **Germany**
    - Nuclear Power Phase out
    - Reduce CO2 Emissions Reduction levels by 25%
    - German Energy Agency Promoting (DENA) Renewable Fuels
    - CHP Incentives for Operators
  - **Korea**
    - Government Focus on Fuel Cells
    - Government Looking to Move to H2 Economy
  - **China**
    - Pollution-7 of 10 most polluted cities are in China
    - 10% of World Energy Consumption

# Accomplishments

## Fuel Cell Power Plant Market Assessment

### Identified Energy Credits and Incentives

<b>CA</b>	<b>SGIP – Level 1 Renewable</b> <b>SGIP - Non-Renewable</b>	\$4.50 / W \$2.50 / W	\$900,000 \$500,000
<b>CA</b>	<b>LADWP – Renewable Fuel</b> <b>LADWP – Non Renewable</b>	\$2.20 – 2.40 / W \$1.20 – 1.90 / W	\$440,000 - \$480,000 \$240,000 – 380,000
<b>CT</b>	<b>CT Project 100</b>	10 Year contract for 5.5 cents/kwhr + wholesale pricing	Must be 1MW project
<b>DE</b>	<b>Green Energy Program</b> <b>Grant - Renewables</b>	Lesser of 50% cost or \$250,000	
<b>NJ</b>	<b>Clean Energy Program -</b> <b>Renewables</b>	\$360,000 - \$855,000	Formula dependent on product size (100 kW – 1 MW)
<b>NJ</b>	<b>Renewable Energy</b> <b>Advanced Power Program</b>	20% of total construction cost	Minimum of 1MW in size. Undergoing revisions, new solicitation in summer 2005
<b>MD</b>	<b>Corporate Tax Credit – Both</b> <b>Renewable and non-</b> <b>Renewable</b>	30% of installed cost, max of \$1.00 / W	\$200,000 – credit carry forward for 10 years
<b>MA</b>	<b>Commercial, Industrial &amp;</b> <b>Institutional Initiative (C31)</b>	\$3.00 - \$4.50 / W	\$650,000 or 50% of construction cost.
<b>OR</b>	<b>Business Energy Tax Credit</b>	35% tax credit taken over 5 years	\$350,000

# Accomplishments

## Power Plant Thermal Integration Study

Reviewed several thermal integration concepts, markets, regional aspects and evaluation methodologies to select **4 primary concepts, 5 markets and 8 regions for systematic evaluation** and identification of high value concepts

- CHP Markets Identified:
  - **Hospitals** - Chilling needs throughout the year and clean environment requirement
  - **Supermarkets** - Dehumidification needs
  - **Data Centers** - Requirements for reliable power and chilling needs
  - **Hotels** - Swimming pools would need dehumidification
  - **Labs/Clean rooms** - Reliable power and 24 hour conditioned air
  
- Regions Selected:
  - **San Francisco, Los Angeles, Chicago, Boston, New York City, Long Island, Miami Washington D.C.**
  - Density of Potential Customers
  - Spark Spread ( Delta between Natural gas and Electrical costs)
  - Geographic Zones, Hot and Humid Areas
  - Areas with \$ Incentives for CHP Applications

# Project Future Work

---

- FY 2005
  - Continue to develop and demonstrate low cost, cell stack components with high durability and reliability
  - Design and manufacture of advanced seals
  - Performance verification of low cost plates and UEAs
  - Complete improved PEM stationary natural gas fueled power plant design based on Lessons Learned
  - Proceed with PSA system (Concept #3) as primary option unless further data from Concepts #1 and #4 suggest otherwise
    - Monitor technological progress as it relates to Concepts #1 and #4
    - Transition Concept #3 to the preliminary design phase
    - PSA purification technology
    - Complete Reformer development tasks
      - Noble metal catalysts
      - Modified tube structure
  - Finalize Thermal Integration study for the useful application of PEM power plant heat

# Project Future Work

---

- FY 2006 – 2009
  - Validate PEM stack components and power plant design concepts in Field Evaluation Power Plant on Grid
  - Begin quantified accelerated testing of advanced membranes to show 40,000 hr durability
  - Continue 20-cell stack demonstration of long life stacks (15,000 Hrs).
  - Stack testing under accelerated, aggressive conditions for lifetime estimation and robustness.
  - Validate PEM power plant performance on feeder systems located in three areas of the U.S: Austin, TX; Albany, NY; and San Francisco CA.
  - Develop predictive base for PEM power plants on various distribution feeders

## Backup Slides

## **The most significant hydrogen hazard associated with this project is:**

Hydrogen leakage within the power plant fuel compartment leads to explosion.

1. Requires multiple failures
2. Multiple layers of protection
3. Very low probability of occurrence



## **Our approach to deal with this hazard is based on CSA FC1, NFPA 496, and NEC:**

1. Design equipment for pressure capability and leakage.
2. Actively monitor hydrogen flow to limit fuel leakage.
3. Ventilate the compartment to less than 25% LFL.
4. Monitor ventilation flow.
5. If necessary,
  - Monitor ventilation exhaust for combustibles
  - Fuel Compartment Fire Detection
  - Provide fail-safe isolation of hydrogen via multiple shutoffs and Normally-closed valves

# Design Process for Safety

- **Safety reviews of product design and product operation**  
Codes and Standards, Hazard Analysis, FMEA, HazOps
- **Layers of Protection Approach**  
Passive, Active, Reactive Mitigations  
Ventilation, Monitoring of Fuel Enclosure, Fuel Interlocks,  
Selection of electrical components in Zone 2 areas
- **Engineering change process applied**  
Cross functional team members review and approve  
Functional verification of hardware/software changes  
Operating procedures under revision control  
Readiness reviews required for major changes, new equipment and chemicals. Highlights:
  - » Hazards analysis and FMEA
  - » Equipment functional checkout
  - » Identification of preventative maintenance
  - » Procedures and Energy Control
  - » PPE assessment, training and communication